

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XE931		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ZIMBAUER, RUDY						Phone # (715)277-2784		1. Well Location				Fire # (if avail.)					
Mailing Address 8027 MILLER LAKE LN						Town of LAKE TOMAHAWK											
City LAKE TOMAHAWK						State WI		Zip Code 54539				Street Address or Road Name and Number TROUT RD					
County Oneida		Co. Permit #		Notification # 46573132		Completed 05-22-2013		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) MERCER WELL DRILLING LLC				Lic. # 6578		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 5789 HWY 51 MERCER WI 54547				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 35 38 N 7 E		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 3		Reason for replaced or reconstructed well ?									
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes						Hicap Property ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		73						- - S -		SAND		Surface		50	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - X -		SAND & CLAY MIX		50		65	
										- - Y -		SAND & GRAVEL		65		73	
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		34 ft. below ground surface		20 in. above grade					
6		NEW BLK ASTM A53 WELDED. 18.97 LBS WHEATLAND				Surface		70		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 39 ft. below surface							
5		JOHNSON 10				70		73		Pumping at 15 GP M for 2 Hrs.							
7. Grout or Other Sealing Material												Pumping Method ?					
Method												12. Notified Owner of need to fill & seal ?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
				Surface						NEW CONSTRUCTION							
13. Constructor / Supervisory Driller												Lic #		Date Signed			
FS														06-05-2013			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 10-17-2013

Updated On: 01-30-2014

Review Status: