

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XE932		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BIELEFELDT, WILLIE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1437 RENEE DR						Town of LAKE TOMAHAWK						6578			
City RACINE						State WI		Zip Code 53406				Street Address or Road Name and Number			
7186 LILLY DR						Subdivision Name				Lot #		Block #			
County Oneida		Co. Permit #		Notification # 47892941		Completed 05-22-2013		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name)				Lic. # 6578		Facility ID # (Public Wells)				45.8126 °N -89.592 °W		GCD013			
Address 5789 HWY 51 MERCER WI 54547				Well Plan Approval #		SE NE		Section 3		Township 38 N		Range 7 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.8		2. Well Type Replacement				of previous unique well #		constructed in	
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?				2IN DRYED UP		Construction Type Drilled	
Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		80											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		63					
- - X -				SAND CLAY MIX				63		75					
- E S -				CLEAN SAND				75		80					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLK ASTM A53 WELDED 18.97 LBS WHEATLAND				Surface		77							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		JOHNSON 10				77		80							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
42 ft. below ground surface															
10. Pump Test															
Pumping level 58 ft. below surface															
Pumping at 12 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
FS				Lic #		Date Signed									
						06-05-2013									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		30

Comment: CITY SEWER

Created On: 06-28-2013

Updated On: 06-30-2020

Review Status: