

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XE933		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner HAHN, TOM					Phone # (920)734-4968		1. Well Location				Fire # (if avail.)					
Mailing Address 416 S FIDELIS ST					Town of HARSHAW					4927						
City APPLETON					State WI		Zip Code 54915					Street Address or Road Name and Number HORSEHEAD RD				
County Oneida		Co. Permit #		Notification # 48051320			Completed 05-30-2013			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) MERCER WELL DRILLING LLC					Lic. # 6578		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 45.704 °N -89.6077 °W			Method Code GCD013			
Address 5789 HWY 51 MERCER WI 54547					Well Plan Approval #			SW NW Section Township Range or Govt Lot # 10 37 N 7 E		2. Well Type Replacement			of previous unique well # constructed in			
Hicap Permanent Well #			Common Well #		Specific Capacity 15			Reason for replaced or reconstructed well ? DRY HOLE								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?			Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
6		Surface		40		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
- - Y -				SAND & GRAVEL				Surface		32						
- A G -				COARSE GRAVEL				32		40						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		NEW BLK ASTM A53 WELDED 18.97 LBS WHEATLAND				Surface		40								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
6		NEW BLK ASTM A53 WELDED 18.97 LBS WHEATLAND				Surface		40								
7. Grout or Other Sealing Material																
Method																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
NA				Surface		40		0								
9. Static Water Level																
24 ft. below ground surface																
10. Pump Test																
Pumping level 25 ft. below surface																
Pumping at 15 GP for 2 Hrs.																
Pumping Method ?																
11. Well Is																
14 in. above grade																
Developed ? Yes																
Disinfected ? Yes																
Capped ? Yes																
12. Notified Owner of need to fill & seal ?																
Filled & Sealed Well(s) as needed? Yes																
13. Constructor / Supervisory Driller																
FS				Lic #				Date Signed 06-05-2013								
Drill Rig Operator				Lic or Reg #				Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 06-28-2013

Updated On: 06-30-2020

Review Status: