

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XE934		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner CARLIN, MIKE						Phone #					
Mailing Address 7496 RIVER RD						Town of LAKE TOMAHAWK					
City LAKE TOMAHAWK						State WI		Zip Code 54539			
County Oneida		Co. Permit #		Notification # 47916145		Completed 05-24-2013		Subdivision Name			
								Lot #		Block #	
Well Constructor (Business Name) MERCER WELL DRILLING LLC				Lic. # 6578		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.7986 °N -89.5628 °W	
Address 5789 HWY 51 MERCER WI 54547				Well Plan Approval #		SE NW		Section 12		Township 38 N	
				Approval Date (mm-dd-yyyy)		Range 7 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.9					
3. Well serves 1 # of				Hicap Well ? No		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Private, potable				Hicap Property ? No							
Heat Exchange ____ # of drillholes				Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		92							
						Rotary - Mud Circulation					
						Rotary - Air					
						Rotary - Air & Foam					
						Drill-Through Casing Hammer					
						Reverse Rotary					
						Cable-tool Bit ____ in. dia...					
						Dual Rotary					
						Temp. Outer Casing ____ in. dia					
						Removed? ____ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
- - Y -				SAND & GRAVEL				Surface		45	
- - X -				SAND & CLAY MIX				45		55	
- - C -				CLAY				55		85	
- A Y -				COARSE SAND & GRAVEL				85		92	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		NEW BLK ASTM A53 WELDED 18.97 LBS WHEATLAND				Surface		92			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
				Surface							
9. Static Water Level											
24 ft. below ground surface											
10. Pump Test											
Pumping level 32 ft. below surface											
Pumping at 15 GP M for 3 Hrs.											
Pumping Method ?											
11. Well Is											
14 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? No											
NEW CONSTRUCTION											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
FS										06-05-2013	
Drill Rig Operator								Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	70	Septic or Holding, or POWTS Tank	>	60

Comment: NO HOUSE YET.

Created On: 06-28-2013

Updated On: 06-30-2020

Review Status: