Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF037

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAISER, SCOTT			Phone #: (715)574-2666
Mailing Address: 815 W 4TH ST			
City: MOSINEE	State: WI	Zip Code: 54455	
County: Marathon	Co. Permit #:	Notification #: 49670418	Completed: 11-26-2013

1. Well Location

Town of EMMET

Fire # (if avail.):

Street Address or Road Name and Number: 817 EAU PLEINE PARK RD

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): WILLIAM D BRUNNER	Lic. #: 515	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 44.79783 °N -89.84055 °W
Address: BRUNNER WELL DRLG, MEDFORD WI 54451-1904		Well Plan Approval #:	Method Code: GPS006
		Approval Date (mm-dd-yyyy):	NE NW or Govt Lot #: Section: 30 Township: 27 N Range: 6 E
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	7
8	7	40
6	40	280

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 3depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - C -	CLAY	Surface	7
R - Q -	RED GRANITE	7	162
K - Q -	BLACK GRANITE	162	280

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. A53B 18.97#/FT. .280 WALL WHEATLAND WELDED JOINTS	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 275 ft. below surface

Pumping at 3 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRAIDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	40	7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WDB		12-02-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		240	Sewer - Building Sanitary		72
Building Overhang		30	Septic or Holding, or POWTS Tank		200

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	11/26/2013	YIELD BEFORE DRY HOLE; AFTER 3 GPM

Created On: 01-02-2014 Updated On: 10-15-2026 Review Status: