Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF039

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: URMANSKI, RICH	Phone #: (715)352-2900
Mailing Address: R4956 CO RD H	
City: EDGAR	State: WI Zip Code: 54426
County: Marathon	Co. Permit #:
Notification #: 49635640	Completed: 11-01-2013
Well Constructor (Business Name): WILLIAM D BRUNNER	Lic. #: 515
Facility ID # (Public Wells):	
Address: BRUNNER WELL DRLG MEDFORD WI 54451-1904	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of RIETBROCK

Fire # (if avail.):

Street Address or Road Name and Number: R240 PINE LN

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.95282 °N -89.97923 °W

Method Code: GPS006

SE NW or Govt Lot #: | Section: 36 | Township: 29 N | Range: 4 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of DAIRY BARN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	44
6	44	180

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air ..... Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	12
G	-	C	-	GRAY CLAY	12	32
-	D	Q	-	DECOMPOSED GRANITE	32	42
-	H	Q	-	FIRM GRANITE	42	62
R	H	Q	-	HARD BLACK GRANITE W/RED LAYERS	62	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. A53B 18.97#/FT. WHEATLAND .280 WALL WELDED JOINTS	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 15 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	44	11 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WDB		11-01-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Manure Hopper or Reception Tank - Liquid Tight		600	Animal Barn Pen		350
Building Overhang		90	Silo/Storage Tube		450
			Barn Gutter		450

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	11/01/2013	WE ARE THE PUMP INSTALLER & SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED

Rehab Type	Rehab Date	Result Text
Hydrofracture	11/01/2013	YIELD BEFORE 3.5 GPM; AFTER 15 GPM

Created On: 02-03-2014 Updated On: 02-03-2014 Review Status: