Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF040

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HESS, PHIL			Phone #: (715)257-9123
Mailing Address: 1175 RAINBOW DR			
City: ATHENS	State: WI	Zip Code: 54411	
County: Marathon	Co. Permit #:	Notification #: 49461634	Completed: 10-07-2013

1. Well Location

Town of HAMBURG

Fire # (if avail.)

Street Address or Road Name and Number: 988 RAINBOW DR

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WILLIAM D BRUNNER	515	

Address: BRUNNER WELL DRLG, MEDFORD WI 54451-1904

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD): 45.10603 °N -89.93543 °W

Method Code: GPS006

SW	SE	Section	Township	Range
or Govt Lot #		5	30 N	5 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: SHORT CASED DRY WELL

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity
		0

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	8
8	8	40
6	40	200

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 8depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	7
-	H	Q	-	FIRM GRANITE	7	22
K	H	Q	-	HARD BLACK GRANITE	22	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. A53B 18.97 #/FT. TTP .280 WALL WELDED JOINTS	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 195 ft. below surface

Pumping at 1 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRAIDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	40	8 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

TO BE DONE WHEN PUMP INSTALLED

13. Constructor / Supervisory Driller	Lic #	Date Signed
WDB		10-15-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Sewer - Building Sanitary		60
Foundation Drain to Clearwater		10	Septic or Holding, or POWTS Tank		66

Comment: OWNER CALLED 061515 & INDICATED DOESN'T KNOW WHAT HE WANTS TO DO W/WELL. WILL MAKE A DECISION ONE OF THESE DAYS.

Created On: 11-15-2013 Updated On: 06-15-2015 Review Status: