Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF135

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAXWELL, MARY	Phone #: (715)824-3680
Mailing Address: 803 WAUPACA RD	
City: OGDENSBURG	State: WI — Zip Code: 54962
County: Waupaca	Co. Permit #:
Notification #: 51906801	Completed: 06-19-2014
Well Constructor (Business Name): MICHAEL O JOHNSON	Lic. #: 545
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: OGDENSBURG WELL DRILLING, OGDENSBURG WI 54962-9704	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.7	

1. Well Location

Village of OGDENSBURG	Fire # (if avail.): 803
Street Address or Road Name and Number: 803 WAUPACA RD PO BOX 27	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.45113 °N -89.03812 °W	Method Code: GPS007
NW SW or Govt Lot #:	Section: 22 — Township: 23 N — Range: 12 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: 8 INCH WELL FROZE & BUSTED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	55

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	I	-	SOFT BLACK TOPSOIL	Surface	1
R	V	X	G	HARD RED CLAY SAND & STONES	1	12
T	S	Y	-	SOFT BROWN MED SAND	12	24
R	H	Z	-	HARD RED CLAY GRAVEL	24	49
I	W	Y	-	SOFT WHITE MED SAND & GRAVEL	49	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW WHEATLAND T&C R&D 19.45 LB PER FOOT ASTM 53	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS 15 SLOT K PACKER JOHNSON	51	55

7. Grout or Other Sealing Material

Method: MOUND POURED DIRECT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENSEAL	Surface		

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 12 GP for 24 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		06-24-2014
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		12
			Septic or Holding, or POWTS Tank		65

Comment:

Created On: 07-24-2014 Updated On: 07-24-2014 Review Status: