# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* XF136

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: SALAN, SCOTT | Phone #: (715)281-8810 |
| Mailing Address: 120 E BADGER ST | |
| City: WAUPACA | State: WI — Zip Code: 54981 |
| County: Waupaca | Co. Permit #: |
| Notification #: 54464743 | Completed: 04-18-2015 |
| Well Constructor (Business Name): MICHAEL O JOHNSON | Lic. #: 545 |
| Facility ID # (Public Wells): | |
| Well Plan Approval #: | |
| Address: OGDENSBURG WELL DRILLING, OGDENSBURG WI 54962-9704 | |
| Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: |
| Specific Capacity: 10 | |

**1. Well Location**

| | |
|---|---|
| Town of FARMINGTON | Fire # (if avail.): E880 |
| Street Address or Road Name and Number: E880 GOLKE RD | |
| Subdivision Name: | Lot #: — Block #: |
| Latitude / Longitude in Decimal Degree (DD): 44.33947 °N -89.18405 °W | Method Code: GPS007 |
| SE NE or Govt Lot #: | Section: 32 — Township: 22 N — Range: 11 E |

**2. Well Type** Replacement

of previous unique well #: — constructed in: 1970

Reason for replaced or reconstructed well ?: POINT PLUGGED

Construction Type: Drilled

**3. Well serves** # of: Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 54 |

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| K | S | I | - | SOFT BLACK TOP SOIL | Surface | 1 |
| T | S | Y | - | SOFT BROWN SAND & GRAVEL | 1 | 10 |
| T | S | C | S | SOFT BROWN CLAY SAND & STONES | 10 | 16 |
| T | S | S | - | SOFT BROWN FINE SAND | 16 | 38 |
| T | W | S | - | SOFT BROWN MED SAND | 38 | 54 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | NEW WHEATLAND T&C R&D 19.45 LBS PER FOOT ASTM 53 | Surface | 50 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 6 | S.S. 12 SLOT K PACKER JOHNSON | 50 | 54 |

**7. Grout or Other Sealing Material**

Method GRAVETY

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENSEAL | Surface | | |

**9. Static Water Level**

24 ft. below ground surface

**10. Pump Test**

Pumping level 26 ft. below surface

Pumping at 20 GP M for 24 Hrs.

Pumping Method ?

**11. Well Is**

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| MJ | | 04-20-2015 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 92 | Downspout/Yard Hydrant | | 20 |
| Building Overhang | | 16 | Septic or Holding, or POWTS Tank | | 77 |

Comment:

Created On: 06-08-2015 Updated On: 05-08-2020 Review Status: