Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF137

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PAULOSKI, TONY	Phone #: (715)445-4606
Mailing Address: N9838 LUND RD	
City: IOLA	State: WI — Zip Code: 54945
County: Waupaca	Co. Permit #:
Notification #: 6397048401	Completed: 08-19-2016
Well Constructor (Business Name): MICHAEL O JOHNSON	Lic. #: 545
Facility ID # (Public Wells):	
Address: OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704	Well Plan Approval #:
	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Village of NORTHLAND	Fire # (if avail.): N9838
Street Address or Road Name and Number: N9838 LUND RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.59545 °N -89.20287 °W	Method Code: GPS007
SW SW or Govt Lot #:	Section: 32 — Township: 25 N — Range: 11 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	72

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	I	-	SOFT BLACK TOP SOIL	Surface	1
T	S	X	-	SOFT BROWN LOAMY SAND	1	10
T	H	Z	G	HARD BROWN CLAY, GRAVEL & BOULDERS	10	27
T	S	Y	-	SOFT TAN SAND & GRAVEL	27	36
G	H	Z	G	GARD GREY CLAY, GRAVEL & STONES	36	40
T	W	Y	C	CLAY, GRAVEL WITH LAYERS WATER SAND & GRAVEL	40	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW WHEATLAND T&C R&D 19.45 LB PER FOOT ASTM 53	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. 12 SLOT K PACKER	68	72

9. Static Water Level

29 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 6 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENSEAL	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		08-22-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		20
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 09-13-2016 Updated On: 05-08-2020 Review Status: