

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XF141		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MORK, JAY						Phone # (715)570-5848		1. Well Location				Fire # (if avail.)	
Mailing Address E1610 HWY B						Village of SCANDINAVIA						E1610	
City SCANDINAVIA						State WI		Zip Code 54977				Street Address or Road Name and Number	
E1610 HWY B						Subdivision Name				Lot #		Block #	
County Waupaca		Co. Permit #		Notification # 55148480		Completed 05-27-2015		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name)				Lic. # 545		Facility ID # (Public Wells)				44.46492 °N -89.15477 °W		GPS007	
Address OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704				Well Plan Approval #		SE SW		Section 15		Township 23 N		Range 11 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 8		2. Well Type Replacement				of previous unique well # constructed in			
3. Well serves 1 # of NEW HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled			
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		41		Rotary - Mud Circulation				Rotary - Air			
						Rotary - Air & Foam				Drill-Through Casing Hammer			
						Reverse Rotary				Cable-tool Bit 6in. dia...			
						Dual Rotary				Temp. Outer Casing ___ in. dia			
						Temp. Outer Casing ___ in. dia				Removed? ___ depth ft. (If NO explain on back side)			
						Yes				No			
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
K		S		I		-		SOFT BLACK TOPSOIL		Surface		1	
T		S		Y		-		SOFT BROWN SAND & GRAVEL		1		7	
T		H		Z		-		HARD BROWN CLAY GRAVEL & STONES		7		14	
T		S		Y		-		SOFT BROWN SAND GRAVEL		14		25	
T		S		Z		-		SOFT BROWN CLAY GRAVEL		25		32	
T		W		Y		-		SOFT BROWN SAND GRAVEL		32		41	
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW WHEATLAND T&C R&D 19.45 LB PER FOOT ASTM53				Surface		37					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		JOHNSON S.S. 12 SLOT K PACKER				37		41					
7. Grout or Other Sealing Material													
Method GRAVITY													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENSEAL				Surface									
9. Static Water Level													
15 ft. below ground surface													
10. Pump Test													
Pumping level 17.5 ft. below surface													
Pumping at 20 GP for 24 Hrs.													
Pumping Method ?													
11. Well Is													
13 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
MJ				06-01-2015									
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Downspout/Yard Hydrant		35

Comment:

Created On: 06-23-2015

Updated On: 05-08-2020

Review Status: