Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XF141

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORK, JAY	Phone #: (715)570-5848
Mailing Address: E1610 HWY B	
City: SCANDINAVIA	State: WI Zip Code: 54977
County: Waupaca	Co. Permit #:
Notification #: 55148480	Completed: 05-27-2015
Well Constructor (Business Name): MICHAEL O JOHNSON	Lic. #: 545
Facility ID # (Public Wells):	
Address: OGDENSBURG WELL DRILLING, OGDENSBURG WI 54962-9704	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 8	

1. Well Location

Village of SCANDINAVIA	Fire # (if avail.): E1610
Street Address or Road Name and Number: E1610 HWY B	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.46492 °N -89.15477 °W	Method Code: GPS007
SE SW or Govt Lot #:	Section: 15 Township: 23 N Range: 11 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of NEW HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	I	-	SOFT BLACK TOPSOIL	Surface	1
T	S	Y	-	SOFT BROWN SAND & GRAVEL	1	7
T	H	Z	-	HARD BROWN CLAY GRAVEL & STONES	7	14
T	S	Y	-	SOFT BROWN SAND GRAVEL	14	25
T	S	Z	-	SOFT BROWN CLAY GRAVEL	25	32
T	W	Y	-	SOFT BROWN SAND GRAVEL	32	41

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW WHEATLAND T&C R&D 19.45 LB PER FOOT ASTM53	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON S.S. 12 SLOT K PACKER	37	41

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENSEAL	Surface		

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 17.5 ft. below surface

Pumping at 20 GP for 24 Hrs.

Pumping Method ?

11. Well Is

13 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		06-01-2015
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Downspout/Yard Hydrant		35

Comment:

Created On: 06-23-2015 Updated On: 05-08-2020 Review Status: