Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XG042

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EMMRICH SPEC NDS TRUST			Phone #
Mailing Address: 7001 TURNING POINT LN			
City: CHARLOTTE	State: NC	Zip Code: 28277	
County: Waupaca	Co. Permit #:	Notification #: 6737371201	Completed: 03-24-2017

Well Constructor (Business Name): WOOLSEY PLBG & HTG INC	Lic. #: 4027	Facility ID # (Public Wells):	
Address: PO BOX 106 WAUPACA WI 54981-0106		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of DAYTON

Fire # (if avail.): E1121

Street Address or Road Name and Number: SNUG HARBOR LN

Subdivision Name:	Lot #: 1	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.32992 °N -89.17172 °W

Method Code: GPS008

NW or Govt Lot #:	NE	Section: 4	Township: 21 N	Range: 11 E
5				

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NOT CODE COMPLYING

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole	Lower Open Bedrock
Rotary - Mud Circulation	
Rotary - Air	
Rotary - Air & Foam	
Drill-Through Casing Hammer	
Reverse Rotary	
Cable-tool Bit ____in. dia...	
Dual Rotary	
Temp. Outer Casing ____in. dia	
Removed? ____depth ft. (If NO explain on back side)	

8. Geology

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2.5	WHITEWATER PITLESS ADAPT.	Surface	3
1.25	GALV. STEEL SCH40	3	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON 60 GA. STAINLESS STEEL	25	28

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

5 ft. below ground surface

10. Pump Test

Pumping level 5 ft. below surface

Pumping at 10 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SJW		03-24-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		10	Shoreline/Pool		25
Building Overhang		2	Sewer - Building Sanitary		25

Comment:

Created On: 05-08-2017 Updated On: 05-08-2020 Review Status: