

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XG582		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ZURAWICZ, BOB						Phone # (608)981-2437		1. Well Location				Fire # (if avail.)					
Mailing Address 163 GOLDEN DR						Town of NEW HAVEN						Street Address or Road Name and Number					
City BRIGGSVILLE						State WI		Zip Code 53920				163 GOLDEN DR					
County Adams		Co. Permit #		Notification # 52904642		Completed 11-02-2014		Subdivision Name				Lot # 3		Block #			
Well Constructor (Business Name) DONALD A HERBECK				Lic. # 229		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.6632 °N -89.6152 °W				Method Code GCD013			
Address A-D WELL & PUMP SERVICE SEXTONVILLE WI 53584				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 25 14 N 7 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? HOLE IN PIPE									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		67		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		T Q C - T - Y -		CAVING TAN CLAY		Surface		55			
2		67		70						TAN SAND & GRAVEL		55		70			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		7 ft. above ground surface				12 in. above grade			
6		WHEATLAND USA ASTM A53BE 6.625X .280 PEL20 CSTNS F61				Surface		67		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 17 ft. below surface				Disinfected ? Yes			
2		304 SS WEDGE 10 SLOT				68		70		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method MOUNDED						Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
#8 CRUMBLES BENTONITE		Surface										2 S					
						13. Constructor / Supervisory Driller		Lic #		Date Signed							
						DAH				11-06-2014							
						Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Sewer - Building Sanitary	>	8
Building Overhang	>	2	Septic or Holding, or POWTS Tank	>	25

Comment: ARTESIAN WELL.

Created On: 01-06-2015

Updated On: 05-04-2020

Review Status: