Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XJ128

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	WIGDALE, THOMAS & KATHLEEN
Phone #	
Mailing Address	W1014 CO RD FF
City	SHEBOYGAN
State	WI
Zip Code	53083
County	Sheboygan
Co. Permit #	
Notification #	53213337
Completed	11-19-2014
Well Constructor (Business Name)	ROGER P WEBER
Lic. #	99
Facility ID # (Public Wells)	
Address	WEBER WELL DRILLING CHILTON WI 53014
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.4

1. Well Location

Town of MOSEL

Fire # (if avail.)

Street Address or Road Name and Number: W1014 CO RD FF

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.8492 °N -87.7466 °W	GCD013

SW	SE	Section	Township	Range
or Govt Lot #		16	16 N	23 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	202

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	102
-	-	L	-	LIMESTONE	102	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL PIPE-NEW 18.97#/FT P.E. EXL TUBE, ASTM A-53-GR B	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 18 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method FLOODED HOLE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	20	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW		11-24-2014
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AK		11-24-2014

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Sewer - Building Sanitary		35
			Septic or Holding, or POWTS Tank		28

Comment:

Created On: 07-29-2015 Updated On: 10-09-2019 Review Status: