

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ128		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner WIGDALE, THOMAS & KATHLEEN						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address W1014 CO RD FF						Town of MOSEL																	
City SHEBOYGAN						State WI		Zip Code 53083				Street Address or Road Name and Number W1014 CO RD FF											
County Sheboygan		Co. Permit #		Notification # 53213337		Completed 11-19-2014		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) ROGER P WEBER				Lic. # 99		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8492 °N -87.7466 °W				Method Code GCD013									
Address WEBER WELL DRILLING CHILTON WI 53014				Well Plan Approval # Approval Date (mm-dd-yyyy)		SW SE		Section 16		Township 16 N		Range 23 E											
						or Govt Lot #																	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type New Well													
										of previous unique well # constructed in													
										Reason for replaced or reconstructed well ?													
3. Well serves 1 # of SHOP				Hicap Well ? No						Construction Type Drilled													
Private, potable				Hicap Property ? No																			
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		20								R - C -		RED CLAY		Surface		102					
6		20		202		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						- - L -		LIMESTONE		102		202					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				16 in. above grade									
6		STEEL PIPE-NEW 18.97#/FT P.E. EXL TUBE, ASTM A-53-GR B				Surface		102		10. Pump Test				Developed ? Yes									
										Pumping level 55 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 18 GP M for 2 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method FLOODED HOLE														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
PUDDLED CLAY				Surface		20		S															
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														RW						11-24-2014			
														Drill Rig Operator				Lic or Reg #		Date Signed			
														AK						11-24-2014			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Sewer - Building Sanitary		35
			Septic or Holding, or POWTS Tank		28

Comment:

Created On: 07-29-2015

Updated On: 10-09-2019

Review Status: