

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ132		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HALBACH, JOHN & TRACY, CEDAR R						Phone # (920)849-4824		1. Well Location				Fire # (if avail.)			
Mailing Address N7363 HARWOOD RD						Town of HARRISON									
City HILBERT						State WI		Zip Code 54129							
County Calumet		Co. Permit #		Notification # 53117170		Completed 10-23-2014		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ROGER P WEBER				Lic. # 99		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1576 °N -88.2458 °W				Method Code GCD013	
Address WEBER WELL DRILLING CHILTON WI 53014				Well Plan Approval #		SE SE		Section 32		Township 20 N		Range 19 E			
						or Govt Lot #									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.6				2. Well Type New Well			
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		20		Rotary - Mud Circulation				Yes					
6		20		162		Rotary - Air				Yes					
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
R - C -		RED CLAY		Surface		34									
- - G -		GRAVEL		34		43									
- - L -		LIMESTONE		43		63									
- - H -		SHALE		63		135									
- - L H		LIMESTONE-SHALE LAYERS		135		162									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL PIPE-NEW 18.97 #/FT P.E. EXL TUBE, ASTM A-53-GR-B				Surface		44							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method FLOODED HOLE															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
PUDDLED CLAY		Surface		20		S									
9. Static Water Level															
20 ft. below ground surface												11. Well Is			
10. Pump Test												16 in. above grade			
Pumping level 55 ft. below surface												Developed ? Yes			
Pumping at 20 GP M for 2 Hrs.												Disinfected ? Yes			
Pumping Method ?												Capped ? Yes			
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller												Lic #		Date Signed	
RW														11-24-2014	
Drill Rig Operator												Lic or Reg #		Date Signed	
AK														11-24-2014	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		107	Sewer - Building Sanitary		60
Building Overhang		30	Septic or Holding, or POWTS Tank		66

Comment:

Created On: 05-06-2015

Updated On: 08-13-2019

Review Status: