

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ218		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KNUDSON, LENORE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W7521 CO HWY ZB						Town of ONALASKA						W7521	
City ONALASKA						State WI		Zip Code 54650				Street Address or Road Name and Number W7521 CO HWY ZB	
County La Crosse		Co. Permit # 32463		Notification # 55875352		Completed 07-10-2015		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) MEDARY DRILLING CO				Lic. # 6703		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9185 °N -91.282 °W		Method Code GCD013	
Address 624 AMY DR HOLMEN WI 54636				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 25 17 N 8 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER SUPPLY					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method						8. Geology							
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
4 Surface 87		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 4in. dia... No Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				- - Y -		SAND & GRAVEL		Surface 87			
6. Casing, Liner, Screen						9. Static Water Level			11. Well Is				
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		38 ft. below ground surface			12 in. above grade						
4 ASTM-A53 T&C 237 WALL 11.00#/FT WHEATLAND PIPE		Surface 84		10. Pump Test			Developed ? Yes						
Dia. (in.) Screen type, material & slot size		From (ft.) To (ft.)		Pumping level 57 ft. below surface			Disinfected ? Yes						
3 STAINLESS STEEL 12 SLOT		84 87		Pumping at 12 GP M for 2 Hrs.			Capped ? Yes						
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?							
Method						Filled & Sealed Well(s) as needed? N/A							
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement		13. Constructor / Supervisory Driller Lic # Date Signed									
NATIVE MATERIAL		Surface		RCS 07-21-2015									
						Drill Rig Operator Lic or Reg # Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Shoreline/Pool		150
Building Drain - Sanitary		15	Sewer - Building Sanitary		15
Building Overhang		6	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 09-04-2015

Updated On: 04-30-2020

Review Status: