

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ221		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DOUENBERG, TED						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N6039 ST RD 162						Town of BURNS						N6039			
City BANGOR						State WI		Zip Code 54614				Street Address or Road Name and Number ST RD 162			
County La Crosse		Co. Permit # 33002		Notification # 56065405		Completed 08-31-2015		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) MEDARY DRILLING CO				Lic. # 6703		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9409 °N -90.9834 °W				Method Code GCD013	
Address 624 AMY DR HOLMEN WI 54636				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 21 17 N 5 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER SUPPLY							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Construction Type Drilled									
3. Well serves 1 # of FARM Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method						8. Geology									
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
4 Surface 45		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 4in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - C - CLAY - - S - SAND				Surface 5 5 45					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		19 ft. below ground surface				12 in. above grade					
4		ASTM A53 T & C .237 WALL 11.00 #/FT WHEATLAND PIPE		Surface 40		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size		From (ft.) To (ft.)		Pumping level 28 ft. below surface Pumping at 12 GP for 2 Hrs. Pumping Method ?									
3		STAINLESS STEEL 12 SLOT		39 45											
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?									
Method						Filled & Sealed Well(s) as needed? Yes									
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement													
NATIVE MATERIAL		Surface 40													
						13. Constructor / Supervisory Driller		Lic #		Date Signed					
						RS				09-10-2015					
						Drill Rig Operator		Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Sewer - Building Sanitary		70
Building Drain - Sanitary		70	Animal Yard - Include Hutches		80
Building Overhang		5	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-11-2015

Updated On: 04-30-2020

Review Status: