

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ228		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BARTHELD, DONNA						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 314 SHELLY LN						Town of CAMPBELL											
City LA CROSSE						State WI		Zip Code 54603									
County La Crosse		Co. Permit # 33037		Notification # 56646518		Completed 10-08-2015		Subdivision Name				Lot # 6 Block # 2					
Well Constructor (Business Name) MEDARY DRILLING CO				Lic. # 6703		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8558 °N -91.2652 °W				Method Code GCD013			
Address 624 AMY DR HOLMEN WI 54636				Well Plan Approval # Approval Date (mm-dd-yyyy)		SW SW		Section 18		Township 16 N		Range 7 W					
						or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 1				2. Well Type Replacement of previous unique well # constructed in							
Reason for replaced or reconstructed well ? WATER SUPPLY																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 4		From (ft.) Surface		To (ft.) 66		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes - - Y -		Type, Caving/Noncaving, Color, Hardness, etc... SAND & GRAVEL		From (ft.) Surface To (ft.) 66			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.) 4		Material, Weight, Specification Manufacturer & Method of Assembly ASTM-A53 T&C 237 WALL 11.00 #/FT EXL TUBE PIPE				From (ft.) Surface		To (ft.) 63		36 ft. below ground surface				14 in. above grade			
Dia. (in.) 3		Screen type, material & slot size STAINLESS STEEL 12 SLOT				From (ft.) 63		To (ft.) 66		10. Pump Test Pumping level 48 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement NATIVE MATERIAL Surface												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller RSS Drill Rig Operator												Lic # Lic or Reg #		Date Signed 10-23-2015 Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		20	Collector Sewer - San or Storm		60
Building Overhang		3	Sewer - Building Sanitary		20

Comment:

Created On: 12-01-2015

Updated On: 04-30-2020

Review Status: