

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XJ600		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PERZ, CHARLES						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N5651 ZINDORF RD						Town of FOUNTAIN						N5651			
City NEW LISBON						State WI		Zip Code 53950				Street Address or Road Name and Number ZINDORF RD			
County Juneau		Co. Permit #		Notification # 53612285		Completed 12-18-2014		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) THOMAS D MCAFEE				Lic. # 6112		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address MCAFEE WELL DRLG & PUMP SERV INC LA VALLE WI 53941-0106				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE		Section 26		Township 16 N		Range 2 E	
								or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 3.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.5 Surface 40			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8.5in. dia... <u>No</u> Dual Rotary <u>Yes</u> Temp. Outer Casing 8.5in. dia <u>Yes</u> Removed? 8depth ft. (If NO explain on back side)												
6 40 135															
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		IPSCO USA P.E. WELDED JOINT ASTM A53B-21 6.625 X 280 DRIVE SHOE INSTALLED				Surface 40									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method GROUT PUMP TREMIE PIPE															
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement									
PORTLAND CEMENT				Surface 40		10 S									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)									
T - S -		BROWN SAND				Surface 8									
T M N -		LT. BROWN SANDSTONE MED HARD				8 38									
T M N -		DARK BROWN SANDSTONE MED. HARD				38 49									
T M N -		LT. BROWN SANDSTONE M. HARD				49 135									
9. Static Water Level															
92 ft. below ground surface															
10. Pump Test															
Pumping level 95 ft. below surface															
Pumping at 10 GP M for 4 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
WASN'T ANY															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
TM				12-30-2014											
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Foundation Drain to Clearwater	>	10
Building Overhang	>	10	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 01-20-2015

Updated On: 01-20-2015

Review Status: