

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XK028		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner VANDELOO, VIC						Phone # (920)766-3186		1. Well Location				Fire # (if avail.)									
Mailing Address 620 HILL RD						Town of HOLLAND															
City GREENLEAF						State WI		Zip Code 54126													
County Brown		Co. Permit #		Notification # 50628211		Completed 03-10-2014		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) WILLEMS WELL DRILLING INC				Lic. # 6155		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.27018 °N -88.16365 °W				Method Code GPS008							
Address 7962 ST PATS CHURCH RD GREENLEAF WI 54126-9611				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 26 21 N 19 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		208		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T S C -		SOFT-CLAY (BROWN)		Surface		44					
6		208		421						T M C -		MEDIUM-CLAY (BROWN)		44		84					
										U Q H -		CAVING-SHALE (BLUE)		84		208					
										G M L -		MEDIUM-LIMESTONE (GRAY)		208		394					
										T M N -		MEDIUM-SANDSTONE (TAN)		394		421					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		130 ft. below ground surface				24 in. above grade							
6		ASTM A-53 GR. B WHEATLAND-WELDED JOINT WT. 18.97 PER FT				Surface		208		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 280 ft. below surface Pumping at 30 GP M for 4 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
DRILLING MUD		Surface		208		S						13. Constructor / Supervisory Driller				Lic #		Date Signed			
												TW				03-12-2014					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		25
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-31-2014

Updated On: 11-21-2019

Review Status: