Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XK028

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VANDELOO, VIC			Phone #: (920)766-3186
Mailing Address: 620 HILL RD			
City: GREENLEAF	State: WI	Zip Code: 54126	
County: Brown	Co. Permit #:	Notification #: 50628211	Completed: 03-10-2014

Well Constructor (Business Name): WILLEMS WELL DRILLING INC	Lic. #: 6155	Facility ID # (Public Wells):
Address: 7962 ST PATS CHURCH RD GREENLEAF WI 54126-9611		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2

1. Well Location

Town of HOLLAND

Fire # (if avail.):

Street Address or Road Name and Number: 620 HILL RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.27018 °N -88.16365 °W				Method Code: GPS008
NE	NW	Section: 26	Township: 21 N	Range: 19 E
or Govt Lot #				

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	208
6	208	421

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation .....
- No / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	C	-	SOFT-CLAY (BROWN	Surface	44
T	M	C	-	MEDIUM-CLAY (BROWN	44	84
U	Q	H	-	CAVING-SHALE (BLUE	84	208
G	M	L	-	MEDIUM-LIMESTONE (GRAY	208	394
T	M	N	-	MEDIUM-SANDSTONE (TAN	394	421

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B WHEATLAND-WELDED JOINT WT. 18.97 PER FT	Surface	208
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

130 ft. below ground surface

10. Pump Test

Pumping level 280 ft. below surface

Pumping at 30 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	208	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		03-12-2014
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		25
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-31-2014 Updated On: 11-21-2019 Review Status: