Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XK029

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BROWN, MARSHA	Phone #: (920)776-1747
Mailing Address: N1732 WOCHOS RD	
City: KEWAUNEE	State: WI — Zip Code: 54216
County: Kewaunee	Co. Permit #:
Notification #: 50736788	Completed: 03-20-2014
Well Constructor (Business Name): WILLEMS WELL DRILLING INC	Lic. #: 6155
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 7962 ST PATS CHURCH RD GREENLEAF WI 54126-9611	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Fire # (if avail.):

Town of FRANKLIN

Street Address or Road Name and Number: N1732 WOCHOS RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.3875 °N -87.6537 °W	GCD013

SW SE or Govt Lot #	Section	Township	Range
	12	22 N	23 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: REPLACED DUG WELL

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	68
6	68	121

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation ..... No

No Rotary - Air ..... Yes

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	M	X	G	MED-CLAY, SAND, GRAVEL	Surface	57
G	M	P	-	MEDIUM-HARD PAN (GRAY	57	67
G	M	L	-	MEDIUM-LIMESTONE (GRAY	67	121

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B WHEATLAND-WELDED JOINT WT. 18.97 PER FT	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 30 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	68	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

ALBRIGHT WILL ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		03-26-2014
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90

Type	Qualifier	Distance
Building Overhang		11
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-17-2014 Updated On: 11-25-2019 Review Status: