

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XK029		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner BROWN, MARSHA						Phone # (920)776-1747		1. Well Location				Fire # (if avail.)											
Mailing Address N1732 WOCHOS RD						Town of FRANKLIN																	
City KEWAUNEE						State WI		Zip Code 54216															
County Kewaunee		Co. Permit #		Notification # 50736788		Completed 03-20-2014		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) WILLEMS WELL DRILLING INC				Lic. # 6155		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3875 °N -87.6537 °W													
Address 7962 ST PATS CHURCH RD GREENLEAF WI 54126-9611				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 12 22 N 23 E		2. Well Type Replacement															
				Approval Date (mm-dd-yyyy)				of previous unique well # constructed in															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? REPLACED DUG WELL																	
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled																	
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
9		Surface		68		<u>Yes</u> Rotary - Mud Circulation <u>No</u>				- M X G		MED-CLAY, SAND, GRAVEL		Surface		57							
6		68		121		<u>No</u> Rotary - Air <u>Yes</u>				G M P -		MEDIUM-HARD PAN (GRAY		57		67							
						Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				G M L -		MEDIUM-LIMESTONE (GRAY		67		121							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				24 in. above grade									
6		ASTM A-53 GR. B WHEATLAND-WELDED JOINT WT. 18.97 PER FT				Surface		68		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ? Yes									
										Pumping at 30 GP M for 4 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method														Filled & Sealed Well(s) as needed? No ALBRIGHT WILL ABANDON									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
DRILLING MUD				Surface		68		S															
13. Constructor / Supervisory Driller														Lic #		Date Signed							
TW																03-26-2014							
Drill Rig Operator														Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		11
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-17-2014

Updated On: 11-25-2019

Review Status: