

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XL423		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCHRANTZ, ANTHONY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 6251 W SHADOW LAKE DR						Town of SCOTT											
City LINO LAKES						State MN		Zip Code 55014									
County Burnett		Co. Permit #		Notification # 6440992701		Completed 06-15-2016		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) CHARLES A ANTILL				Lic. # 6101		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.94767 °N -92.0458 °W				Method Code GPS008			
Address 27737 CTY A SPOONER WI 54801				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 13 40 N 14 W				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NEEDED NEW WELL							
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Construction Type Drilled											
3. Well serves 1 # of CABIN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		123		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T Q Y -		SAND & GR, C, LT BR, SOFT		Surface		40	
5		123		T M X -						SAND & CLAY, BR, MED		40		60			
				T H X -						CLAY & SAND, BR, HARD		60		100			
				T H C -						CLAY, BR, HARD		100		120			
				T M S -						SAND, BR, MED		120		126			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				16 in. above grade			
6		EXLTUBE WELDED 280 WALL A53B 19 LBS PER FT				Surface		123		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 100 ft. below surface Pumping at 6 GP M for 10 Hrs. Pumping Method ?							
5		12 SLOT STAINLESS STEEL				123		126									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed? Yes NOT HIRED FOR THAT											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
		Surface															
						13. Constructor / Supervisory Driller		Lic #		Date Signed							
						CA											
						Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Sewer - Building Sanitary		25
Shoreline/Pool		70	Septic or Holding, or POWTS Tank		28

Comment:

Created On: 01-23-2017

Updated On: 08-03-2017

Review Status: