Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XM213

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROWLES, MIKE	Phone #: (631)219-1638
Mailing Address: N2087 BONNIE LN	
City: MARINETTE	State: WI / Zip Code: 54143
County: Marinette	Co. Permit #:
Notification #: 6807155101	Completed: 05-12-2017
Well Constructor (Business Name): BRYAN G KOZIKOWSKI	Lic. #: 56
Facility ID # (Public Wells):	
Address: KOZIKOWSKI WELL & PUMP, MENOMINEE MI 49858	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.9	

1. Well Location

Town of PESHTIGO	Fire # (if avail.): N2087
Street Address or Road Name and Number: N2087 BONNIE LN	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0344 °N -87.717 °W	Method Code: GCD013
NW NW or Govt Lot #	Section: 33 / Township: 30 N / Range: 23 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

SLOW PRODUCTION SAND POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	37
6	37	40

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	27
-	-	Z	G	CLAY GRAVEL STONE	27	37
-	-	L	-	LIMESTONE	37	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM A53-B WHEATLAND & WELDED JOINTS	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

9.5 ft. below ground surface

10. Pump Test

Pumping level 14 ft. below surface

Pumping at 13 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMMIE LINE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	37	7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		06-05-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		90

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Well Construction	04/27/2017	<REQUIRED CASING

Created On: 06-20-2017 Updated On: 10-22-2019 Review Status: