Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XM214

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAGNER, BRUCE	Phone #: (715)732-4929
Mailing Address: N5315 HWY 180	
City: MARINETTE	State: WI Zip Code: 54143
County: Marinette	Co. Permit #:
Notification #: 6836381001	Completed: 09-08-2017
Well Constructor (Business Name): BRYAN G KOZIKOWSKI	Lic. #: 56
Facility ID # (Public Wells):	
Address: KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 13	

1. Well Location

Town of PORTERFIELD	Fire # (if avail.): W2309
Street Address or Road Name and Number: W2309 NETTLETON RD	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.13529 °N -87.71425 °W	Method Code: GPS006

SE	SW	Section	Township	Range
or Govt Lot #		24	31 N	22 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40
6	40	65

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	11
-	-	C	G	CLAY & STONE	11	20
-	-	C	-	CLAY	20	23
-	-	C	G	CLAY & STONE	23	32
-	B	L	-	LIMESTONE BROKEN	32	35
-	-	L	-	LIMESTONE	35	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL, 18.97 ASTM A53-B WHEATLAND WELDED JOINTS	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 21 ft. below surface

Pumping at 13 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE LINE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	40	7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		09-12-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 10-09-2017 Updated On: 10-09-2017 Review Status: