

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				<b style="font-size: 1.2em;">XM214		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WAGNER, BRUCE						Phone # (715)732-4929		1. Well Location				Fire # (if avail.) W2309							
Mailing Address N5315 HWY 180						Town of PORTERFIELD						Street Address or Road Name and Number W2309 NETTLETON RD							
City MARINETTE			State WI		Zip Code 54143		Subdivision Name				Lot #		Block #						
County Marinette		Co. Permit #		Notification # 6836381001		Completed 09-08-2017		Latitude / Longitude in Decimal Degree (DD) 45.13529 °N -87.71425 °W				Method Code GPS006							
Well Constructor (Business Name) BRYAN G KOZIKOWSKI				Lic. # 56		Facility ID # (Public Wells)				SE SW Section Township Range or Govt Lot # 24 31 N 22 E									
Address KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858				Well Plan Approval #		Approval Date (mm-dd-yyyy)				2. Well Type New Well									
Hicap Permanent Well #				Common Well #		Specific Capacity 13				Reason for replaced or reconstructed well ?									
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		40		<u>Yes</u> Rotary - Mud Circulation <u>No</u>				- - S - SAND				Surface		11			
6		40		65		<u>No</u> Rotary - Air <u>Yes</u>				- - C G CLAY & STONE				11		20			
						Rotary - Air & Foam				- - C - CLAY				20		23			
						Drill-Through Casing Hammer				- - C G CLAY & STONE				23		32			
						Reverse Rotary				- B L - LIMESTONE BROKEN				32		35			
						Cable-tool Bit ____ in. dia...				- - L - LIMESTONE				35		65			
						Dual Rotary													
						Temp. Outer Casing ____ in. dia													
						Removed? ____ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				24 in. above grade					
6		BLACK STEEL, 18.97 ASTM A53-B WHEATLAND WELDED JOINTS				Surface		40		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 21 ft. below surface				Disinfected ? Yes					
										Pumping at 13 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMIE LINE PUMPED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
CEMENT				Surface		40		7 S											
13. Constructor / Supervisory Driller								Lic #		Date Signed									
BK										09-12-2017									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 10-09-2017

Updated On: 10-09-2017

Review Status: