Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XM218

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ALBRIGHT JR, HAROLD	Phone #: (715)923-1264
Mailing Address: N3232 CO RD D	
City: PESHTIGO	State: WI — Zip Code: 54157
County: Marinette	Co. Permit #:
Notification #: 6507650601	Completed: 07-19-2016
Well Constructor (Business Name): BRYAN G KOZIKOWSKI	Lic. #: 56
Facility ID # (Public Wells):	
Address: KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of PESHTIGO	Fire # (if avail.): N3232
Street Address or Road Name and Number: CO D	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0755 °N -87.765 °W	Method Code: GCD013
NW NE or Govt Lot #:	Section: 13 — Township: 30 N — Range: 22 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SLOW SANDPOINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	57
6	57	248

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

No — Rotary - Air ..... — Yes

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	14
-	-	Z	S	SANDY CLAY & STONE	14	57
-	-	L	H	LIMESTONE & SHALE	57	140
-	-	N	-	SANDSTONE	140	142
-	-	L	N	LIMESTONE SANDSTONE SHALE	142	162
-	-	N	-	SANDSTONE	162	165
-	-	L	H	LIMESTONE SANDSTONE SHALE	165	248

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	57	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		07-22-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AT		07-22-2016

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 08-18-2016 Updated On: 10-22-2019 Review Status: