

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XM222		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner COLE, SHERWOOD						Phone # (715)735-6538		1. Well Location				Fire # (if avail.)			
Mailing Address N2274 SHORE DR						Town of PESHTIGO						N2274			
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number N2274 SHORE DR			
County Marinette		Co. Permit #		Notification # 6507643801		Completed 08-18-2016		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) BRYAN G KOZIKOWSKI				Lic. # 56		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0413 °N -87.6258 °W			Method Code GCD013		
Address KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858				Well Plan Approval #		Approval Date (mm-dd-yyyy)				NW SE		Section Township		Range	
										or Govt Lot # 3		30 30 N		24 E	
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type Replacement					
Reason for replaced or reconstructed well ? SAND POINT SLOW PRODUCTION															
3. Well serves 1 # of						Hicap Well ?		Construction Type Drilled							
Private, potable						Hicap Property ?									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 128			Yes Rotary - Mud Circulation No												
6 128 550			No Rotary - Air Yes												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
			Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		26					
- - S C				SAND W/CLAY LAYERS				26		32					
- - C -				CLAY				32		125					
- - L -				LIMESTONE				125		155					
- - L H				LIMESTONE & SHALE				155		470					
- - L N				LIMESTONE, SANDSTONE, SHALE				470		550					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		BLACK STEEL, 18.97 ASTM A53-B WHEATLAND WELDED JOINTS				Surface		128							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material										9. Static Water Level					
Method										20 ft. below ground surface					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				11. Well Is					
DRILLING MUD & CUTTINGS		Surface		128		S				24 in. above grade					
										Developed ? Yes					
										Disinfected ? Yes					
										Capped ? Yes					
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?										Yes					
STILL IN USE															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
BK										09-06-2016					
Drill Rig Operator								Lic or Reg #		Date Signed					
AT										09-06-2016					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		60	POWTS dispersal component (soil absorption unit or mound)		35
			Ditch or Culvert		5

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	07/13/2016	<REQUIRED 50' FROM SEPTIC DRAINFIELD & < 8' FROM DITCH

Created On: 10-14-2016

Updated On: 10-22-2019

Review Status: