

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XM974		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner NEW HORIZON HOMES						Phone #		1. Well Location				Fire # (if avail.)													
Mailing Address 575D N KNOWLES AVE						Town of CLIFTON						Street Address or Road Name and Number 1245TH ST													
City NEW RICHMOND				State WI		Zip Code 54017																			
County Pierce		Co. Permit #		Notification # 54933374		Completed 05-04-2015		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) MARTELL STEVE PUMPS & WELL DRLG INC				Lic. # 105		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code											
Address PO BOX 28 SOMERSET WI 54025-0028				Well Plan Approval #				NE NW Section Township Range or Govt Lot # 1 27 N 20 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
				Approval Date (mm-dd-yyyy)																					
Hicap Permanent Well #				Common Well #		Specific Capacity 2				3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes															
Hicap Well ? No Hicap Property ? No Hicap Potable ?				Hicap Well ? No Hicap Property ? No Hicap Potable ?																					
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method														8. Geology											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)							
10 Surface 42			Rotary - Mud Circulation											- - C -		CLAY		Surface 15							
6 42 200			No Rotary - Air Yes Yes Rotary - Air & Foam No Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											- - L -		LIMEROCK		15 200							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		125 ft. below ground surface				14 in. above grade											
6		18.99 #/FT ASTM A53 NEW PRIME PE IPSCO				Surface		42		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 130 ft. below surface Pumping at 10 GP for 1 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
6		18.99 #/FT ASTM A53 NEW PRIME PE IPSCO				Surface		42		12 S															
7. Grout or Other Sealing Material														13. Constructor / Supervisory Driller				Lic #				Date Signed			
Method TREMIE PIPE PUMPED																									
Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement NEAT CEMENT Surface 42 12 S																									
Drill Rig Operator														Lic or Reg #				Date Signed							
SF														SF				SF							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		28

Comment:

Created On: 07-29-2015

Updated On: 07-29-2015

Review Status: