Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XN463

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BANGSUND, TIM		Phone #: (952)201-8452
Mailing Address: 24387 LIND RD		
City: SIREN	State: WI	Zip Code: 54872

County	Co. Permit #	Notification #	Completed
Burnett		6553419201	10-03-2016

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
GARY C BEECROFT	137	

Address: GARY BEECROFT WELL DRLG & WATER SYS
SIREN WI 54872-9604

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
	463	3.4

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of SIREN

Fire # (if avail.): 24387

Street Address or Road Name and Number: 24387 LIND RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.79943 °N -92.366 °W	GPS008

NE NE or Govt Lot #	Section	Township	Range
	8	38 N	16 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	169.5

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	M	SILTY SAND & CLAY	Surface	8
-	-	M	-	SILTY	8	68
-	-	P	-	HARDPAN	68	157
-	-	Y	-	SAND & GRAVEL	157	169.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 NORTHERN	Surface	165.33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL 25 SLOT	165.33	169.5

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	160	12 S

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 75 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		10-12-2016
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang		15
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-09-2016 Updated On: 11-09-2016 Review Status: