

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XN463		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner BANGSUND, TIM						Phone # (952)201-8452		1. Well Location				Fire # (if avail.)											
Mailing Address 24387 LIND RD						Town of SIREN						24387											
City SIREN						State WI		Zip Code 54872				Street Address or Road Name and Number 24387 LIND RD											
County Burnett		Co. Permit #		Notification # 6553419201		Completed 10-03-2016		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) GARY C BEECROFT				Lic. # 137		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.79943 °N -92.366 °W				Method Code GPS008											
Address GARY BEECROFT WELL DRLG & WATER SYS SIREN WI 54872-9604				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 8 38 N 16 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME Construction Type Drilled															
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well # 463		Specific Capacity 3.4																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 169.5		Upper Enlarged Drillhole <u>Yes</u> Rotary - Mud Circulation <u>No</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Lower Open Bedrock		Geology Codes - - X M SILTY SAND & CLAY - - M - SILTY - - P - HARDPAN - - Y - SAND & GRAVEL		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) Surface 8 68 157 169.5		To (ft.) 8 68 157 169.5							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.) 5		Material, Weight, Specification SDR17 NORTHERN				From (ft.) Surface		To (ft.) 165.33		18 ft. below ground surface				12 in. above grade									
Dia. (in.) 4		Screen type, material & slot size STAINLESS STEEL 25 SLOT				From (ft.) 165.33		To (ft.) 169.5		10. Pump Test Pumping level 40 ft. below surface Pumping at 75 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
7. Grout or Other Sealing Material Method TREMIE Kind of Sealing Material EZ SEAL From (ft.) Surface To (ft.) 160 # Sacks Cement 12 S														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
13. Constructor / Supervisory Driller GB Drill Rig Operator										Lic # Lic or Reg #		Date Signed 10-12-2016 Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang		15
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-09-2016

Updated On: 11-09-2016

Review Status: