Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XN464

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LYNDON, JEROME			Phone #: (715)225-2859
Mailing Address: 6022 CO HWY M S			
City: ELK MOUND	State: WI	Zip Code: 54739	
County: Burnett	Co. Permit #:	Notification #: 6798618601	Completed: 06-01-2017

Well Constructor (Business Name): GARY C BEECROFT	Lic. #: 137	Facility ID # (Public Wells):	
Address: GARY BEECROFT WELL DRLG & WATER SYS SIREN WI 54872-9604		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of SCOTT

Fire # (if avail.): 29117

Street Address or Road Name and Number: 29117 BROZIE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.96863 °N -92.11038 °W	GPS008

SW	NW	Section	Township	Range
or Govt Lot #		9	40 N	14 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	229

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	-	SAND & CLAY	Surface	14
-	-	Y	-	SAND & GRAVEL	14	36
-	-	G	G	GRAVEL & BOULDERS	36	135
-	-	Z	S	SANDY CLAY & ROCKS	135	218
-	-	Y	-	SAND & GRAVEL	218	229

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NORTHERN SDR17 PVC	Surface	224.83
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	STAINLESS STEEL 18 SLOT	224.83	229

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	220	17.5 S

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 75 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		06-14-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		27

Comment:

Created On: 07-13-2017 Updated On: 06-30-2020 Review Status: