

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XN465		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BROWN, KELLY & SHAWN						Phone # (612)245-2961		1. Well Location				Fire # (if avail.)							
Mailing Address 28281 JOHNSON LAKE RD						Town of OAKLAND						27464							
City WEBSTER						State WI		Zip Code 54893				Street Address or Road Name and Number							
27464 E CONNORS LK RD						Subdivision Name				Lot #		Block #							
County Burnett		Co. Permit #		Notification # 6851316401		Completed 10-31-2017		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) GARY C BEECROFT						Lic. # 137		Facility ID # (Public Wells)				45.91207 °N -92.29698 °W		GPS008					
Address GARY BEECROFT WELL DRLG & WATER SYS SIREN WI 54872-9604						Well Plan Approval #		SE NW		Section 36		Township 40 N		Range 16 W					
						Approval Date (mm-dd-yyyy)		or Govt Lot #		36		40 N		16 W					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3		2. Well Type Replacement											
Reason for replaced or reconstructed well ?						NEEDED MORE WATER													
3. Well serves # of CATTLE WATER						Hicap Well ? No		Construction Type Drilled											
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		148.25		Yes Rotary - Mud Circulation		No		- - X -		SAND & CLAY		Surface		11			
						Rotary - Air				- - Y -		SAND & GRAVEL		11		72			
						Rotary - Air & Foam				- - P -		HARD PAN		72		132			
						Drill-Through Casing Hammer				- - Y -		SAND & GRAVEL		132		148.25			
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				12 in. above grade					
5		NORTHERN SDR17 PVC				Surface		143.75		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface				Disinfected ? Yes					
4		25 SLOT STAINLESS STEEL				143.75		148.25		Pumping at 40 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMIE												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
EZ SEAL				Surface		132		11 S		GB						11-03-2017			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		3	Animal Yard - Include Hutches	>	50

Comment:

Created On: 12-21-2017

Updated On: 12-21-2017

Review Status: