Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XO275

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BINA, WAYNE & TAMMIE	Phone #: (507)313-5438
Mailing Address: 100 AVON RD TRLR 114	
City: SPARTA	State: WI — Zip Code: 54656
County: Jackson	Co. Permit #:
Notification #: 55437373	Completed: 06-03-2015
Well Constructor (Business Name): MARK A MAURER	Lic. #: 4806
Facility ID # (Public Wells):	
Address: MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4	

1. Well Location

Town of IRVING	Fire # (if avail.): N3555
Street Address or Road Name and Number: NICHOLS RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1968 °N -90.8968 °W	Method Code: GCD013
SE NE or Govt Lot #:	Section: 19 — Township: 20 N — Range: 4 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of POLE BUILDING

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - I -	BROWN TOPSOIL	Surface	2
T Q Y -	TAN SAND & GRAVEL-CAVING	2	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S.S. TELESCOPE - 10 SLOT	33	38

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MM		06-19-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment: NO SEPTIC

Created On: 07-10-2015 Updated On: 05-01-2020 Review Status: