

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XO275		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner BINA, WAYNE & TAMMIE Phone # (507)313-5438						1. Well Location				Fire # (if avail.) N3555		
Mailing Address 100 AVON RD TRLR 114 City SPARTA State WI Zip Code 54656						Town of IRVING Street Address or Road Name and Number NICHOLS RD						
County Jackson		Co. Permit #		Notification # 55437373		Completed 06-03-2015		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) MARK A MAURER				Lic. # 4806		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.1968 °N -90.8968 °W			Method Code GCD013	
Address MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 19 20 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 4								
3. Well serves 1 # of POLE BUILDING Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)		
6		Surface		38		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T - I - BROWN TOPSOIL Surface 2 T Q Y - TAN SAND & GRAVEL-CAVING 2 38		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 15 ft. below ground surface		
6		P.E. BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA				Surface		33		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 20 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?		
5		S.S. TELESCOPE - 10 SLOT				33		38				
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Surface												
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?												
13. Constructor / Supervisory Driller								Lic #		Date Signed		
MM										06-19-2015		
Drill Rig Operator								Lic or Reg #		Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment: NO SEPTIC

Created On: 07-10-2015

Updated On: 05-01-2020

Review Status: