

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XO276		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GERDES, BRETT & AMY Phone # (612)669-0444						1. Well Location				Fire # (if avail.)				
Mailing Address 646 KAYLA LN						Town of ALMA								
City HANOVER State MN Zip Code 55341						Street Address or Road Name and Number GARAGE RD								
County Jackson		Co. Permit #		Notification # 55750133		Completed 07-03-2015		Subdivision Name			Lot #	Block #		
Well Constructor (Business Name) MARK A MAURER				Lic. # 4806	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code				
Address MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839				Well Plan Approval #		NE NE	Section 12	Township 22 N	Range 4 W					
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
3. Well serves 1 # of CAMPER Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock							
6	Surface	82	Rotary - Mud Circulation <u>No</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)		
							T	-	I	-	BROWN TOPSOIL		Surface	2
							T	Q	X	-	BROWN SAND & CLAY-CAVING		2	37
							T	H	N	-	TAN SANDSTONE-HARD		37	82
6. Casing, Liner, Screen														
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	9. Static Water Level 50 ft. below ground surface				11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
6	P.E. BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA				Surface	38								
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	10. Pump Test Pumping level 82 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?		
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement										
		Surface												
13. Constructor / Supervisory Driller												Lic #	Date Signed	
MM													07-15-2015	
Drill Rig Operator												Lic or Reg #	Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO BLDG OR SEPTIC

Created On: 09-04-2015

Updated On: 11-02-2015

Review Status: