Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XO276

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERDES, BRETT & AMY	Phone #: (612)669-0444
Mailing Address: 646 KAYLA LN	
City: HANOVER	State: MN Zip Code: 55341

County	Co. Permit #	Notification #	Completed
Jackson		55750133	07-03-2015

Well Constructor (Business Name): MARK A MAURER	Lic. #: 4806	Facility ID # (Public Wells)
Address: MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5

1. Well Location

Town of ALMA

Fire # (if avail.)

Street Address or Road Name and Number: GARAGE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE or Govt Lot #	NE	Section	Township	Range
		12	22 N	4 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CAMPER

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	82

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - I -	BROWN TOPSOIL	Surface	2
T Q X -	BROWN SAND & CLAY-CAVING	2	37
T H N -	TAN SANDSTONE-HARD	37	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 82 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MM		07-15-2015
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO BLDG OR SEPTIC

Created On: 09-04-2015 Updated On: 11-02-2015 Review Status: