

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XO278		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner STOLTZFUS, SAMUEL						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W11792 BUSH RD						Town of ALBION											
City BLACK RIVER FALLS						State WI		Zip Code 54615									
County Jackson		Co. Permit #		Notification # 56014394		Completed 08-03-2015		Street Address or Road Name and Number ROBBINS RD									
Subdivision Name						Lot #		Block #									
Well Constructor (Business Name) MARK A MAURER				Lic. # 4806		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839				Well Plan Approval #		SW SE		Section 25		Township 21 N		Range 5 W					
						or Govt Lot #											
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.6				2. Well Type New Well					
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?											
Heat Exchange ___ # of drillholes				Construction Type Drilled													
3. Well serves 1 # of Private, potable																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 6		From (ft.) Surface		To (ft.) 142		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology							
						Rotary - Mud Circulation				Geology Codes T - I -		Type, Caving/Noncaving, Color, Hardness, etc... BROWN TOPSOIL		From (ft.) Surface		To (ft.) 2	
						Rotary - Air		Yes		T Q S -		BROWN SAND-CAVING		2		37	
						Rotary - Air & Foam				T H N -		TAN SANDSTONE-HARD		37		142	
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen																	
Dia. (in.) 6		Material, Weight, Specification PE BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA				From (ft.) Surface		To (ft.) 38		9. Static Water Level		11. Well Is					
										110 ft. below ground surface		24 in. above grade					
										10. Pump Test		Developed ? Yes					
										Pumping level 142 ft. below surface		Disinfected ? Yes					
										Pumping at 20 GP for 1 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.) Surface		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
										Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller								Lic #		Date Signed							
MM										08-04-2015							
Drill Rig Operator								Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO BLDG-NO SEPTIC

Created On: 09-04-2015

Updated On: 11-05-2015

Review Status: