Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XO278

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STOLTZFUS, SAMUEL	Phone #
Mailing Address: W11792 BUSH RD	
City: BLACK RIVER FALLS	State: WI — Zip Code: 54615
County: Jackson	Co. Permit #: — Notification #: 56014394 — Completed: 08-03-2015
Well Constructor (Business Name): MARK A MAURER	Lic. #: 4806 — Facility ID # (Public Wells):
Address: MAURER WELL DRLG LLC BLACK RIVER FALLS WI 54615-5839	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Fire # (if avail.):

Town of ALBION

Street Address or Road Name and Number: ROBBINS RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SE or Govt Lot #: — Section: 25 — Township: 21 N — Range: 5 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole — Lower Open Bedrock

Rotary - Mud Circulation .....

No — Rotary - Air ..... — Yes

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - I -	BROWN TOPSOIL	Surface	2
T Q S -	BROWN SAND-CAVING	2	37
T H N -	TAN SANDSTONE-HARD	37	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE BLACK STEEL-ASTM A53 18.97/FT-IPSCO USA	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

110 ft. below ground surface

10. Pump Test

Pumping level 142 ft. below surface

Pumping at 20 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MM		08-04-2015
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO BLDG-NO SEPTIC

Created On: 09-04-2015 Updated On: 11-05-2015 Review Status: