Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XP432

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAHONEY, MICHAEL	Phone #
Mailing Address: S67 W14596 GAUKE CT	
City: MUSKEGO	State: WI — Zip Code: 53150
County: Adams	Co. Permit #: — Notification #: 57281868 — Completed: 12-01-2015
Well Constructor (Business Name): QUINNELL'S QUALITY SEPTICS INC	Lic. #: 7257 — Facility ID # (Public Wells):
Address: 1852 HWY Z ARKDALE WI 54613	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of ROME	Fire # (if avail.): 423
Street Address or Road Name and Number: DUFFERS TRL	
Subdivision Name:	Lot #: 19 — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1948 °N -89.81073 °W	Method Code: SCR002
SE NW or Govt Lot #:	Section: 20 — Township: 20 N — Range: 6 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Jetted

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	48
1.25	48	52

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	42
-	N	S	-	FINE SAND	42	52

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHITEWATER PITLESS	Surface	6
2	WHEATLAND ASTM A53A T & C	6	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	CAMPBELL 80 GAUZE	48	52

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SAND	Surface		

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? No

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
CQ		12-02-2015
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Wastewater Sump	>	50

Comment:

Created On: 12-22-2015 Updated On: 05-04-2020 Review Status: