Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XP944

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CROZIER, BRANDON	Phone #: (216)502-0381
Mailing Address: W274 N7291 HAZEL WAY	
City: SUSSEX	State: WI — Zip Code: 53089
County: Waukesha	Co. Permit #: — Notification #: 54772368 — Completed: 04-22-2015
Well Constructor (Business Name): BOWLING RAY INC	Lic. #: 6200 — Facility ID # (Public Wells):
Address: N9061 BEGGAN LN, WATERTOWN WI 53094	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Fire # (if avail.):

Town of LISBON

Street Address or Road Name and Number: W274 N7291 HAZEL WAY

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.1501 °N -88.2925 °W — Method Code: GCD013

SW SE or Govt Lot #: — Section: 18 — Township: 8 N — Range: 19 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	67
4	67	70

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Z	G	BROWN CLAY ROCKS-STONES	Surface	8
T	-	Y	-	BROWN SAND GRAVEL	8	55
G	-	G	S	GRAY SANDY GRAVEL	55	62
T	-	G	S	BR. SANDY GRAVEL	62	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 6.625 X 280 A-53 IPSCO WELDED	Surface	67
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	S/S 15 SLOT PACKER 4IN NIP	67	70

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 25 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		04-22-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Drain - Sanitary	>	30
Building Overhang		12
Clearwater Sump	>	25
Downspout/Yard Hydrant		8
Foundation Drain to Clearwater		12
Wastewater Sump		30
Sewer - Building Sanitary	>	40
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-23-2015 Updated On: 07-12-2019 Review Status: