Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XP945

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MARTIN, STEVE	Phone #: (920)988-1010
Mailing Address: 1512 COUNTRY CLUB LN	
City: WATERTOWN	State: WI — Zip Code: 53098
County: Dodge	Co. Permit #:
Notification #: 54907474	Completed: 04-28-2015
Well Constructor (Business Name): BOWLING RAY INC	Lic. #: 6200
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N9061 BEGGAN LN WATERTOWN WI 53094	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 20	

1. Well Location

Town of EMMET

Fire # (if avail.):

Street Address or Road Name and Number: 1512 COUNTRY CLUB LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.2321 °N -88.7266 °W	GCD013

NE SW or Govt Lot #	Section	Township	Range
	21	9 N	15 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - Z G	BR. CLAY ROCKS STONES	Surface	15
G - C G	GRAY CLAY STONES	15	65
G - L -	GRAY LIMESTONE	65	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 6.625 X 280 ASTM A53 IPSCO WELDED	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 CRUMBLES	Surface		

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 100 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		04-28-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	>	25	Collector Sewer - San or Storm	>	80
Building Overhang		10	Downspout/Yard Hydrant		10
Clearwater Sump		35	Foundation Drain to Clearwater		11
			Sewer - Building Sanitary	>	30

Comment:

Created On: 07-10-2015 Updated On: 10-01-2019 Review Status: