

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XQ501		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner MINKS, JEAN						Phone # (715)258-5152		1. Well Location				Fire # (if avail.)		
Mailing Address N2171 CO RD K						Town of DAYTON						N2171		
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number N2171 CO RD K		
County Waupaca		Co. Permit #		Notification # 6717575001		Completed 04-13-2016		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) NEAL D LOEHRKE				Lic. # 133		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.31817 °N -89.11067 °W				Method Code GPS008		
Address VALLEY WELL DRILLING WEYAUWEGA WI 54983				Well Plan Approval #		SW SE		Section 1		Township 21 N		Range 11 E		
Approval Date (mm-dd-yyyy)				or Govt Lot #		2. Well Type Replacement								
Hicap Permanent Well #				Common Well #		Specific Capacity 0.9		of previous unique well # constructed in						
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?								
Private, potable				Hicap Property ? No		MORE CAPACITY NEEDED								
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		145		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
						Yes No								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
-	-	Y	-	SAND & GRAVEL				Surface		18				
-	-	C	S	SANDY CLAY				18		103				
-	N	S	-	FINE FINE SAND				103		127				
-	-	Z	P	CLAY GRAVEL (HARDPAN)				127		143				
-	-	Q	-	GRANITE? I THINK				143		145				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				
6		STEEL 18.97LBS/FT A-53 GRB EXLTUBE WELDED				Surface		109		13 ft. below ground surface				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is				
6		TELE S.S 8 SLOT				109		125		24 in. above grade				
7. Grout or Other Sealing Material										10. Pump Test				
Method GRAVITY										Pumping level 29 ft. below surface				
Kind of Sealing Material										Pumping at 15 GP M for 40 Hrs.				
CAVING SAND & DRILL CUTTINGS										Pumping Method ?				
From (ft.) To (ft.) # Sacks Cement										Filled & Sealed Well(s) as needed?				
Surface										Yes				
VWD FILL/SEALED 2 INCHES OUTSIDE REPORT ATTACHED										13. Constructor / Supervisory Driller				
Lic #										Date Signed				
ND L										04-13-2016				
Drill Rig Operator										Lic or Reg #				
Date Signed										04-13-2016				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-27-2016

Updated On: 05-08-2020

Review Status: