Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XR178

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHMAUS, GARY			Phone #
Mailing Address: W156 N11375 PILGRIM RD			
City: GERMANTOWN	State: WI	Zip Code: 53022	
County: Portage	Co. Permit #:	Notification #: 56370957	Completed: 09-09-2015

Well Constructor (Business Name): JOSEPH FARAGO	Lic. #: 284	Facility ID # (Public Wells):	
Address: FARAGO PLBG & TRENCHING INC PLAINFIELD WI 54966		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of PINE GROVE				Fire # (if avail.): 5445
Street Address or Road Name and Number: CO RD W				
Subdivision Name: BANCROFT ASSESSOR PLAT #1			Lot #: 10	Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3073 °N -89.5157 °W				Method Code: GCD013
NE SE or Govt Lot #:	Section: 11	Township: 21 N	Range: 8 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
PLUGGED POINT

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	27

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - S -	SAND	Surface	30

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND GALV. THREADED & COUPLED WEIGHT-101.3	Surface	27
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	S & S #10	27	30

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
11 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 8 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		09-09-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	52
Building Overhang		3

Type	Qualifier	Distance
Sewer - Building Sanitary	>	10
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-11-2015 Updated On: 05-07-2020 Review Status: