

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XR546		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner GOLDBECK, BRANDON						Phone # (262)302-1121		1. Well Location				Fire # (if avail.)					
Mailing Address 14018 N DAVIS RD						City of MEQUON						Street Address or Road Name and Number 14018 N DAVIS RD					
City MEQUON				State WI		Zip Code 53097											
County Ozaukee		Co. Permit #		Notification # 6717560101		Completed 03-04-2016		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) JAMES H GROTH				Lic. # 4935		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 43.273 °N -88.0213 °W			Method Code GCD013					
Address 9197 EDGE O'WOODS DR CEDARBURG WI 53012				Well Plan Approval #			SW NW Section Township Range or Govt Lot # 4 9 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology					
8		Surface		110		<u>Yes</u> Rotary - Mud Circulation <u>No</u>			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)					
6		110		203		<u>No</u> Rotary - Air <u>Yes</u>			- - C - CLAY			Surface 108					
Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)						- - L - LIMESTONE			108 203								
						6. Casing, Liner, Screen						9. Static Water Level			11. Well Is		
						Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)		15 ft. below ground surface			12 in. above grade	
						6		18.97 # ASTM A-53 EXL TUBE P.E.			Surface 110		10. Pump Test			Developed ? Yes	
						Dia. (in.)		Screen type, material & slot size			From (ft.) To (ft.)		Pumping level 60 ft. below surface			Disinfected ? Yes	
						Pumping at 20 GP M for 1 Hrs.						Pumping Method ?			Capped ? Yes		
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed?											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
DRILLING MUD		Surface		110		S		13. Constructor / Supervisory Driller Lic # Date Signed JG 03-07-2016 Drill Rig Operator Lic or Reg # Date Signed									
Method																	
Method																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Foundation Drain to Clearwater		25
Building Drain - Sanitary		40	Wastewater Sump		40
Building Overhang		25	Sewer - Building Sanitary		45
Clearwater Sump		38	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-08-2016

Updated On: 07-15-2019

Review Status: