Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XR546

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GOLDBECK, BRANDON			Phone #: (262)302-1121
Mailing Address: 14018 N DAVIS RD			
City: MEQUON	State: WI	Zip Code: 53097	
County: Ozaukee	Co. Permit #:	Notification #: 6717560101	Completed: 03-04-2016

1. Well Location

City of MEQUON

Fire # (if avail.)

Street Address or Road Name and Number: 14018 N DAVIS RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JAMES H GROTH	4935	

Latitude / Longitude in Decimal Degree (DD): 43.273 °N -88.0213 °W

Method Code: GCD013

SW	NW	Section	Township	Range
or Govt Lot #		4	9 N	21 E

Address: 9197 EDGE O'WOODS DR
CEDARBURG WI 53012

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #:

Common Well #:

Specific Capacity: 0.4

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	110
6	110	203

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No / Yes
- No — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	108
-	-	L	-	LIMESTONE	108	203

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 # ASTM A-53 EXL TUBE P.E.	Surface	110
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	110	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JG		03-07-2016
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		40
Building Overhang		25
Clearwater Sump		38

Type	Qualifier	Distance
Foundation Drain to Clearwater		25
Wastewater Sump		40
Sewer - Building Sanitary		45
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-08-2016 Updated On: 07-15-2019 Review Status: