

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XR547		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner TISLJAR, ROBERT						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 9100 W HIGHLAND RD								City of MEQUON									
City MEQUON						State WI		Zip Code 53097									
County Ozaukee		Co. Permit #		Notification # 57980634		Completed 02-17-2016		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) JAMES H GROTH				Lic. # 4935		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 9197 EDGE O'WOODS DR CEDARBURG WI 53012				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 16 9 N 21 E											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		2. Well Type New Well				of previous unique well # constructed in					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		50		<u>Yes</u> Rotary - Mud Circulation		<u>No</u>		- - C S		SANDY CLAY		Surface		14	
6		50		145		<u>No</u> Rotary - Air		<u>Yes</u>		- - L -		LIMESTONE		14		145	
						Rotary - Air & Foam											
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. below ground surface		12 in. above grade					
6		18.97 #ASTM A-53 EXL TUBE P.E.				Surface		50		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface		Disinfected ? Yes					
										Pumping at 12 GP M for 1 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?							
NEAT CEMENT GROUT				Surface		50		8 S									
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JG				03-07-2016	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Clearwater Sump		55
Building Drain - Sanitary		28	Foundation Drain to Clearwater		15
Building Overhang		16	Sewer - Building Sanitary		39
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-08-2016

Updated On: 04-08-2016

Review Status: